



## SECTION 04 20 00

### MASONRY ACCESSORIES – Weep Vents

#### **PART 1 GENERAL**

##### 1.1 SECTION INCLUDES

- A. Weep Vents.

##### 1.2 RELATED SECTIONS

- A. Section 04 20 00 – Clay Unit Masonry: Cavity wall construction of brick veneer.

##### 1.3 REFERENCES

- A. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials.

##### 1.4 SUBMITTALS

- A. Submit under provisions of Section 01 33 00.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
  1. Preparation instructions and recommendations.
  2. Storage and handling requirements and recommendations.
  3. Installation methods.

##### 1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Minimum 2 years production of similar products.
- B. Installer Qualifications: Minimum 2 years experience as a masonry installer.

##### 1.6 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.

#### **PART 2 PRODUCTS**

##### 2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Keene Building Products; PO Box 241353, Mayfield Heights, Ohio 44124. Toll Free Tel: (877) 514-5336, Tel: (440) 605-1020. Fax: (440) 605-1120. Email: [info@keeneBuilding.com](mailto:info@keeneBuilding.com). Web: <http://www.KeeneBuilding.com>.
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01 25 00.

##### 2.2 WEEP VENTS

- A. Weep Vents: Polyester non-woven mesh vent that is placed in the vertical head joints approximately every two feet to create a space for moisture to drain and vent in a brick cavity wall.

B. Product: Driwall™ Weep Vents as manufactured by Keene Building Products.

C.

1. Description:
  - a. 2.5" x 3.5" x 0.375"
  - b. Polyester

### **PART 3 EXECUTION**

#### **3.1 INSTALLATION**

- A. Place weep vents in open head joints of cavity wall located immediately above ledges and flashing, spaced 24 inches apart, unless otherwise shown.

END OF SECTION